


1. ALL HOMERUNS ARE TO BE 3/4" CONDUIT MINIMUM, UNLESS OTHERWISE NOTED. 2. ALL CONDUCTORS SHALL BE #12 UNLESS OTHERWISE NOTED. 3. ALL CONDUITS SHALL CONTAIN A GROUND CONDUCTOR SIZED PER NEC.


CIRCUITING SYMBOLS




1. VERIFY ALL MOUNTING HEIGHTS WITH CABO/ANSI A117.1, U.F.A.S. REQUIREMENTS AND ALL OTHER APPLICABLE CODES. 2. COORDINATE MOUNTING HEIGHTS WITH ALL ARCHITECTURAL PLANS, ELEVATIONS AND DETAILS PRIOR TO ROUGH-IN. INFORM ARCHITECT OF ANY CONFLICTS.

2 STANDARD MOUNTING HEIGHTS

NTS




BELOW GRADE CONDUIT




NOTES:


1. ALL GROUNDING AND BONDING CONDUCTORS SHALL BE IN ACCORDANCE WITH NEC 250. 2. VERIFY EXISTING BONDING JUMPER AT SERVICE ENTRANCE EQUIPMENT PDS-33 AND MAKE CONNECTION PER NEC. FEEDER TO BUILDING 33, FROM SERVICE EQUIPMENT SHALL CONTAIN AN EQUIPMENT GROUNDING CONDUCTOR. COMPLY WITH NEC 250.32(B) FOR SEPARATE STRUCTURES. SEE SINGLE-LINE FOR REQUIREMENTS.

GROUNDING DETAIL



5 CONDUIT TRAPEZE MOUNTING DETAIL





PRELIMINARY CONSTRUCTION

ELECTRICAL DETAILS	PROJECT TITLE VAMC ENERGY UPG PHASE ONE		33
APPROVED: DIVISION CHIEF	BUILDING NUMBER 33	CHECKED AKD	drawn DJf

APPROVED: SERVICE DIRECTOR

LOCATION

BOISE, IDAHO

531-10-114

DEPARTMENT OF VETERANS AFFAIRS

250 S. 5TH ST. • BOISE, ID 83702 (208) 343-4635 • FAX (208) 343-1858 http://www.cshqa.com

THESE DRAWINGS AND SPECIFICATIONS, AS INSTRUMENTS OF SERVICE, ARE AND SHALL REMAIN THE PROPERTY OF THE ARCHITECT / ENGINEER WHETHER THE PROJECT FOR WHICH THEY ARE MADE IS EXECUTED OR NOT. THESE DRAWINGS AND SPECIFICATIONS SHALL NOT BE USED BY ANY PERSON OR ENTITY ON OTHER PROJECTS, FOR ADDITIONS TO THIS PROJECT, OR COMPLETION OF THIS PROJECT-WHEN PHASED-WITHOUT THE WRITTEN CONSENT OF CSHQA OR ITS AFFILIATES. Copyright 92011

C.W. MOORE PLAZA